



The RTVC3P controls the automatic system for correction of the power factor. It is a KVAR based controller which controls up to 16 capacitor banks optimally to achieve near unity power factor and also measures/calculates various electrical parameters. RTVC3P is meant for use in three phase four wire electrical systems. The main features of the RTVC3P are:

## **Comprehensive Poly Phase Measurement**

The RTVC3P needs three CT inputs from the mains and also all the three phase and neutral connections. So, in addition to accurate control of VAR, this model also provides comprehensive electrical measurement. The parameters measured and displayed are all voltages, currents, power factor, system PF, active power, apparent power, reactive power, active energy, apparent energy, average PF maintained since last reset and THD figures for voltages and currents. This model also gives LED pulse output of 1000 impulses/Unit for KWh and KVAh separately.

### **Ease of Installation**

CT primary and secondary of Mains as well as Capacitor, PT Gain, switching time of control action (250mS, 500mS, 1 Second, 2 Second) and target PF are site programmable. RTVC3P has an autosense feature, which senses the sizes of the capacitor banks connected on each stage automatically. No need to program bank sizes manually.

### **Low Current Operation**

Since there is no fixed sequence of switching capacitors, if very small capacitor banks are connected, RTVC3P sense down to 0.4% and 2% of the main load and take corrective action in VAR mode and FIFO/SFIFO mode respectively.

#### **Intelligent Control**

The control parameter is VAR, and not PF. Target PF value is just used to calculate the capacitive VAR required to be added/removed to achieve the desired PF. e.g. If the target PF is unity, means that the target VAR in the system is zero. If system KVAR is 200 lagging, then the controller needs to add 200 KVAR of capacitor banks to reach zero VAR.

The calculation of the reactive power in the system is done by taking instantaneous samples of all voltage and current waveforms, in all four quadrants. These values are then subjected to DSP techniques to add a frequency independent 90° phase shift to current samples. The product of these voltage and current samples then generate signed VAR value.

VAR controller takes into calculation the prevailing system KVAR, the prevailing bank KVAR and the bank sizes of each stage, and then switches ON/OFF the combination which is closest to the needed VAR.

## **Switching Time of Control Action**

The Switching Time is selectable from one of the following values: 250mS, 500mS, 1 Second and 2 Second. RTVC3P is fast enough to sense load fluctuation and take action accordingly at programmed Switching Time but its fast switching performance totally depends on external factors like TSM & Capacitor bank discharge resistors. Needlessly selecting fast switching times for slow varying loads, without adequate attention to using correctly sized fast discharge resistors can cause control loop instability and PF may not be achieved.

# **Technical Specifications**

Parameters			
Туре		Name	Statistics
		Supply	Three Phases and Neutral of a 3P4W system
INPUT		Voltage	Direct Voltage Input : Up to 280V L-N PT Ratio : Site Selectable Burden : 0.5VA
		Current	Secondary Current Input : 5A or 1A (Site Selectable)  CT Ratio : Site Selectable  Range of Reading : 5−5000A  Burden : <1.0VA  Overload : 5A CT → 6A RMS  Continuous  : 1A CT → 1.2A RMS  Continuous
		Power Supply	Self powered from Mains
	True RMS Basic Parameters	Voltage (Volts L-N : VRN, VYN, VBN)	Accuracy : 0.5% of Reading
		Current (Amps IR, IY, IB)	Accuracy : 0.25% of Reading
		Line Frequency	45 to 55 Hz, Accuracy : 0.3% of Reading
	Power	Active Power (P)	Accuracy : 1% of Reading (For IPFI>0.5)
MENT		Reactive Power (Q)	Accuracy : 1.5% of Reading (Between 0.5 Lag to 0.8 Lead)
MEASUREMENT		Apparent Power (S)	Accuracy : 1% of Reading
		Power Factor	For Individual phases and System Accuracy : 1.0% of Reading (IPFI≥0.5) Range of Reading : 0.05 to 1.00 Lag/Lead
	Energy	Total Active Energy (KWh)	Range of Reading : 0 to 9999999.9 Accuracy : Class 1.0s as per IS13779
		Total Apparent Energy (KVAh)	Range of Reading : 0 to 9999999.9  Accuracy : 1.0% of Reading
	Power Quality	3 <sup>rd</sup> to 15 <sup>th</sup> Harmonics (Odd) for all voltages with THD 3 <sup>rd</sup> to 15 <sup>th</sup> Harmonics (Odd) for all currents with THD	
MISCELLANEOUS	Dimensions	Bezel Panel Cutout Depth of installation Display Operating temp Weight Min. Operating Current	144 X 144 mm  138 X 138 mm  55 mm  128 x 64 graphical backlit LCD  10°C to 50°C  0.600 Kg (Approx)  VAR Mode : 0.4% of CT primary FIFO/SFIFO Mode : 2.0% of CT primary
	Comm	Calibration LED	Red Colour. 1000 impulses/Unit
	Comm.	RS485	Modbus-RTU protocol

<sup>\*</sup> Note: To be specified at the time of ordering

#### TRINITY ENERGY SYSTEMS PVT. LTD.

386, Savli G.I.D.C Estate, Manjusar-391775,
Dist.-Vadodara, Gujarat, India. Tele: +91-9228004452/53/54
E-Mail: info@trinityenergy.co.in

web : www.trinityenergy.co.in







